

RAMP REQUIREMENTS


- Ramps serving dwellings shall be a minimum of 36" clear width. Commercial ramps shall be a minimum of 48" in clear width.
- The surface slope of the ramp shall not exceed a slope of 1' in 12'
- The top landing shall be a minimum of 60" x 60".
- 4. Bottom landings shall be a minimum of 72" long in the ramp direction and shall be at least as wide as the ramp.
- 5. Intermediate landings shall be at least 60" long in the ramp direction.
- 6. Intermediate landings which change the direction of the ramp shall be at least 60" x 60".
- 7. Surface of the ramp shall be roughened or constructed of slip-resistant material.
- 8. Ramps and landings which have drop-offs or ramps exceeding 10' in length and not bounded by a wall or fence, shall have edge protection consisting of either a guide curb a minimum of 2" in height or a wheel guide rail centered 3" plus or minus 1" on each side of the ramp. (NOTE: When a drop-off exceeds 4" in height, the guide curb must be increased to project a minimum of 6" above the ramp and landing surfaces.



NOTE 1: WHEN DOOR SWINGS ONTO LANDING - 42" MIN. PLUS DOOR WIDTH NOTE 2: MAXIMUM HORIZONTAL DISTANCE OF EACH RAMP AND RUN YARY




RAMP WITH TURNING PLATFORM (WHEN DIRECTION OF RAMP CHANGES 30 DEGREES OR MORE)



STRAIGHT RAMP RUN

30 DEGREE OR GREATER ANGLE



RAMP WITH INTERMEDIATE SWITCH-BACK PLATFORM

LANDING