

County of Tehama
Department of Environmental Health
633 Washington St., Rm 36
Red Bluff CA 96080
Phone # (530) 527-8020
www.co.tehama.ca.us

OFFICIAL FOOD INSPECTION REPORT



Tim Potanovic, REHS - Director

Facility Name	: MYSHEL'S QUICKBITE CAFE	Owner	: MICHELLE BISSONNETTE
Site Address	: 17597 STAGECOACH RD	Owner Address	: 17597 STAGECOACH RD
Facility ID	: FA0001312	Inspector	: EE0000001 - David Brower
Record ID	: PR0002289	Inspector Phone	: Not Specified
License/Permit Number	: PT0002380	Program:	: 1640 - Limited Food Prep (Coffee Stand/Hotel)
Person in Charge	:	Total Inspection Time	: 75 min.
Inspection Date	: 8/18/2015	Result	: 01 - Meets Standards
Inspection Number	: DA0003387		
Purpose of Inspection	: 102 - Routine Inspection		

An inspection of your property revealed the following violations. Please note the date for reinspection. Thank you for your cooperation.

Inspection Violations

ALL VENTILATION SHALL MEET REQUIREMENTS - 16 38B

"Comply by Date" Not
Specified

Not In Compliance

Violation Description:

Exhaust hoods shall be provided to remove toxic gases, heat, grease, vapors and smoke and be approved by the local building department. Canopy-type hoods shall extend 6# beyond all cooking equipment. All areas shall have sufficient ventilation to facilitate proper food storage. Toilet rooms shall be vented to the outside air by a screened openable window, an air shaft, or a light-switch activated exhaust fan, consistent with local building codes. (114149, 114149.1)

Corrective Description:

Inspector Comments:

Please Note That New Hood Will Be Required By 11-05-2015!!!!

Overall Inspection Comments

Facility very Clean!! All Temps Good!!

Received By: _____

Date _____

David Brower _____

Date _____