

County of Tehama
Department of Environmental Health
633 Washington St., Rm 36
Red Bluff CA 96080
Phone # (530) 527-8020
www.co.tehama.ca.us

OFFICIAL INSPECTION REPORT



Tim Potanovic, REHS - Director

Facility Name	: TAPIA'S CAMP	Owner	: TAPIAS CAMP
Site Address	: 3261 ORCHARD AVE	Owner Address	: 22080 CORNING RD
Facility ID	: FA0000704	Inspector	: EE0000004 - Don Shellock
Record ID	: PR0000361	Inspector Phone	: Not Specified
License/Permit Number	: 2909-24H-1	Program:	: 2410 - Organized Camp
Person in Charge	:		:
Inspection Date	: 8/30/2016	Total Inspection Time	: 40 min.
Inspection Number	: DA0004375	Result	: 02 - Failed To Meet Standards
Purpose of Inspection	: 102 - Routine Inspection		

An inspection of your property revealed the following violations. Please note the date for reinspection. Thank you for your cooperation.

Inspection Violations

PROPER BACKFLOW PROTECTION - 16 41

"Comply by Date" Not Specified

Not In Compliance

Violation Description:

The potable water supply shall be protected with a backflow or back siphonage protection device, as required by applicable plumbing codes. (114192) All plumbing and plumbing fixtures shall be installed in compliance with local plumbing ordinances, shall be maintained so as to prevent any contamination, and shall be kept clean, fully operative, and in good repair. Any hose used for conveying potable water shall be of approved materials, labeled, properly stored, and used for no other purpose. (114171, 114189.1, 114190, 114193, 114193.1, 114199, 114201, 114269)

Corrective Description:

Inspector Comments:

Provide vacuum breaker at kitchen sink to prevent possible back siphon.

POTENTIALLY HAZARDOUS FOODS HOLD TEMPERATURES - 16 7

"Comply by Date" Not Specified

Not In Compliance

Violation Description:

Potentially hazardous foods shall be held at or below 41/ 45°F or at or above 135°F. (113996, 113998, 114037, 114343(a))

Corrective Description:

Inspector Comments:

Area of Concern: Be sure all cold units are at 41°F or below before stocking.

Overall Inspection Comments

At the time of inspection Environmental Health has not received the annual water test results.

Received By:

Date

Don Shellock

Date